

LEAD AND COPPER TESTING IN SCHOOLS

PROFILE

As part of its continued efforts to safeguard public health, the City of Keene has completed lead testing at all school districts and some licensed childcare facilities within its jurisdiction. The testing was conducted in accordance with the Environmental Protection Agency's (EPA) Lead and Copper Rule, which establishes strict limits on allowable lead levels in drinking water. Laboratory results confirmed that all sampled locations were well below the EPA's maximum contaminant level of 15 parts per billion (ppb), ensuring the safety of drinking water for students and young children.

Protecting the health of our community, especially our children, is a top priority. We will continue regular monitoring and maintenance to keep it that way.

The City tested water samples from multiple fixtures, including drinking fountains and kitchen taps, in accordance with EPA protocols. A full summary of the test results is available on the City of Keene's website and has been shared with school and childcare administrators. The City remains committed to transparency, community health, and environmental responsibility, and will continue to take proactive steps to ensure clean, safe drinking water for all.



CONTACT

☎ 817-641-3336

💬 Justin Hollenbach

✉ pwadmin@keenetx.com

🌐 <https://www.keenetx.com/>

SCHOOLS/ DAYCARES

- Keene Elementary
- Keene Junior High
- Keene High School
- Keene Little Leaders
- Mary's Daycare
- Keene Adventist Elementary
- Chisholm Trail Academy

LINKS

EPA – Basic Info about Lead and Drinking Water

<https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>

Schools/ Daycares	Sample Site	Copper MCL	Copper Results	Lead MCL	Lead Results
Keene Elementary	KEB1	1.3 mg/L	0.0755mg/L	0.015mg/L	<0.001mg/L
Keene Elementary	KEB2	1.3 mg/L	0.255mg/L	0.015mg/L	<0.001mg/L
Keene Elementary	KEG1	1.3 mg/L	0.214mg/L	0.015mg/L	<0.001mg/L
Keene Elementary	KEWF	1.3 mg/L	0.157mg/L	0.015mg/L	<0.001mg/L
Keene Elementary	KEBR	1.3 mg/L	0.239mg/L	0.015mg/L	<0.001mg/L
Keene Junior High	KJHF1	1.3 mg/L	0.0921mg/L	0.015mg/L	<0.001mg/L
Keene Junior High	KJHBR1	1.3 mg/L	0.178mg/L	0.015mg/L	<0.001mg/L
Keene Junior High	KJHBRB	1.3 mg/L	0.169mg/L	0.015mg/L	<0.001mg/L
Keene Junior High	KJHF2	1.3 mg/L	0.0798mg/L	0.015mg/L	<0.001mg/L
Keene Junior High	KJHBR2	1.3 mg/L	0.0603mg/L	0.015mg/L	<0.001mg/L
Keene High School	KHGB1	1.3 mg/L	0.334mg/L	0.015mg/L	<0.001mg/L
Keene High School	KHWBF	1.3 mg/L	0.186mg/L	0.015mg/L	<0.001mg/L
Keene High School	KHWF	1.3 mg/L	0.146mg/L	0.015mg/L	<0.001mg/L
Keene High School	KHGB2	1.3 mg/L	0.0782mg/L	0.015mg/L	<0.001mg/L
Keene High School	KH CAFÉ	1.3 mg/L	0.122mg/L	0.015mg/L	<0.001mg/L
Keene Little Leaders	KDC01	1.3 mg/L	0.227mg/L	0.015mg/L	<0.001mg/L
Keene Little Leaders	KDC02	1.3 mg/L	0.0702mg/L	0.015mg/L	<0.001mg/L
Mary's Daycare	MARYS DC	1.3 mg/L	0.0219mg/L	0.015mg/L	<0.001mg/L
Mary's Daycare	MARYS DC 2	1.3 mg/L	0.0536mg/L	0.015mg/L	<0.001mg/L
Keene Adventist Elementary	KAE B1	1.3 mg/L	0.434mg/L	0.015mg/L	<0.001mg/L
Keene Adventist Elementary	KAE G1	1.3 mg/L	0.361mg/L	0.015mg/L	<0.001mg/L
Keene Adventist Elementary	KAE GF1	1.3 mg/L	0.216mg/L	0.015mg/L	<0.001mg/L
Keene Adventist Elementary	KAE BREAK	1.3 mg/L	0.286mg/L	0.015mg/L	<0.001mg/L
Keene Adventist Elementary	KAE CAFÉ	1.3 mg/L	0.383mg/L	0.015mg/L	<0.001mg/L
Chisholm Trail Academy	CTA F1	1.3 mg/L	0.0708mg/L	0.015mg/L	<0.001mg/L
Chisholm Trail Academy	CTA F2	1.3 mg/L	0.167mg/L	0.015mg/L	<0.001mg/L
Chisholm Trail Academy	CTA G1	1.3 mg/L	0.0727mg/l	0.015mg/L	0.00146mg/L
Chisholm Trail Academy	CTA NGF	1.3 mg/L	0.275mg/L	0.015mg/L	<0.001mg/L
Chisholm Trail Academy	CTA BB	1.3 mg/L	0.0834mg/L	0.015mg/L	<0.001mg/L